

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-20-01-17-01

**Product:** SPC Flooring, Top layer: PVC, UV coating, Structure: BP  
Dimensions: 1220 mm x 180 mm x 4.0 mm  
Distributed by: WUXI HANYANG INTERNATIONAL TRADE CO., LTD.  
NO. 40 Renmin South Road, Luoshe Town, Huishan District, Wuxi

**Producer:** W.Z.N.D.M. for EuroTec Next

**Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)

**Test report:** 2719396

**Test results:** *The above mentioned SPC Flooring can be classified regarding to the tested properties according to EN 14041:2008 (CE-labelling) as follows:*

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	11.6 kW / m <sup>2</sup> 701 % x min	Reaction to fire class Bfl-s1
Sliding behavior according to EN 13893:2003	$\mu = 0.62$	class DS
Formaldehyde emission according to EN 717-1:2005	< LOD (240 h)	class E1

\* LOD = Limit of Detection

Dresden, 17/01/2020

  
Head of laboratory



  
Engineer in charge